

Chehalis Elders Center

Addendum # 3

June 25, 2021

NOTICE TO ALL BIDDERS:

Owner: The Chehalis Tribe
P.O. Box 536
Oakville, WA 98568

Project Manager: Bryan Sanders (360) 709-1813

Contact: ARC Architects
Project Manager: Ariel Jamison (206) 322-3322

To All Bidders: Attention is called to the following items effective June 25, 2021, which shall be added to, deleted from, or changed from the BID DOCUMENTS dated April 16, 2021, thereby incorporating the addendum as part of the CONTRACT DOCUMENTS.

A. GENERAL NOTES - NONE

B. PROJECT MANUAL

1. SECTION 282300 – VIDEO SURVEILLANCE
 - A. Delete Specification Section 282300. Owner will provide Video Surveillance System including cameras, cables and other accessories. Contractor shall provide rough-in only for Video Surveillance System per Sheet Note #1 on Sheet E5.1.

B. SUBSTITUTIONS - NONE

C. DRAWINGS

1. Structural Drawings – The following question was included in Addendum 02 as item C.6.B and was answered incorrectly. Please use the response below.
 - A. Sheet S4.02, Detail N.
 - a. **QUESTION:** There is no weld information shown for the steel baseplates at the peeler poles (reference N/S4.02). Please clarify welding requirements.
 - b. **ANSWER:** HSS to plate connections to be continuous 3/8" fillet welds all around. Knife plate to base plate connection to be 3/8" fillet weld each side

D. ATTACHMENTS - NONE

END OF ADDENDUM #3